

NOTES:

1. To be read in conjunction with all other MXF information.
2. This drawing shows the scope and intent of luminaire requirements in external areas, not the full extent of ancillaries required for a complete installation.
3. External lighting requirements comply with the following standards and guidelines:
 - BS EN 5489-1
 - BS EN 8300-2
 - CIBSE guide LG6 & LG9
 - BS EN 13201
4. Public road lighting to comply with BS EN13201. New public road to be classed as a P4 system.
5. Landscape architect to confirm the extent of the courtyard walkways.

LEGEND:

Key	Area Served	Lux Level	Ref.	Luminaire Reference	Fed Via
	Commonal Entrances	50 Lux	CIBSE Guide LG9	EX.2	Landlord DB
	Private Amenity	30 Lux	CIBSE Guide LG9	EX.2	Apartment Consumer Unit
	Commonal External Courtyard	10 Lux	CIBSE Guide LG9	EX.1	Landlord Feeder
	Public Road	5 Lux	BS 13201	EX.1	ESB Micro Pillar



Outline of Approved Planning Application
Ref no. 3164/23



client: Dublin City Council
job no.: J6928 TB
project leader: TB
scale at A1: 1:100
status code and description: For Planning

project: Dublin City Housing VB3 - St Andrew's Court
drawing title: External Lighting Strategy
Level 00
Sitewide
External Lighting Strategy

issue date: 03/07/24
revision: P02
classification: SS_70_80_25_00
project code: SAC - MXF - ZZ - 00 - DR - E - 31000

© Copyright Max Fordham LP