



Key	Area Served	Lux Level	Ref.	Luminaire Reference	Fed Via
	Roof Access	10 Lux	CIBSE	Guide LG9	EX.5
	Communal Roof Terrace	10 Lux	CIBSE	Guide LG9	EX.2
	Landlord DB				
	Landlord DB				

**LEGEND:**

1. To be read in conjunction with all other MXF information.
2. This drawing shows the scope and intent of luminaire requirements in external areas, not the full extent of ancillaries required for a complete installation.
3. External lighting requirements comply with the following standards and guidelines:
- BS EN 5489-1
  - BS EN 8300-2
  - CIBSE guide LG6 & LG9
  - BS EN 13201
4. Public road lighting to comply with BS EN13201. New public road to be classed as a P4 system.
5. Landscape architect to confirm the extent of the courtyard walkways.

**NOTES:**

Outline of Approved Planning Application Ref no. 3164/23

Outline of Approved Planning Application Ref no. 3164/23