



LEGEND:

Key	Area Served	Lux Level	Ref.	Luminaire Reference	Fed Via
	Private Amenity	30 Lux	CIBSE	Guide LG9	Apartment Consumer Unit
	Communal Deck Access	50 Lux	CIBSE	Guide LG9	Landlord DB

- NOTES:**
- To be read in conjunction with all other MXF information.
 - This drawing shows the scope and intent of luminaire requirements in external areas, not the full extent of ancillaries required for a complete installation.
 - External lighting requirements comply with the following standards and guidelines:
 - BS EN 5489-1
 - BS EN 8300-2
 - CIBSE guide LG6 & LG9
 - BS EN 13201
 - Public road lighting to comply with BS EN13201. New public road to be classed as a P4 system.
 - Landscape architect to confirm the extent of the courtyard walkways.

Outline of Approved Planning Application
Ref no. 3164/23

Outline of Approved Planning Application
Ref no. 3164/23