

ISSUE	DATE:	NOTE:									
-	16/02/2024	Issue for planning.									
This document needs to be read in conjuncture with the general arrangement drawings, component drawings, method statement and the photographic survey. Refer to the Fire consultant report and drawings for further details.											
Note: Door numbers for existing doors is aligned with the proposed door numbering, therefore existing door numbers are not sequential.											
FLOOR	DOOR NO.	LOCATION	STATUS	MATERIAL	FIRE RATING UPGRADE REQUIRED	EXISTING ARCHITRAVE	DESCRIPTION OF EXISTING CONDITION	VISION PANEL	NEW PROPOSED DOOR TYPE (WHERE APPLICABLE)	IRONMONGERY - TBD	NOTES
EXTERNAL DOORS											
BASEMENT	EDB-01	B-06/ B-07	Retain	Historic door		Yes	Histroic iron door, in bad state of conservation and taken off the hinges	No			To be restored, repainted by a specialist blacksmith. In addition to the restored dood a new 30 minute fire door to be added in the location to meet current regulations.
	ED0-01	0-04 / Castle street	Retain			Yes	Historic panelled timber door within a stone architrave	No	N/A		Stone surround around the door architrave. The proposed plans show the door orientation reversed to swing out. Minor repairs required.
	ED0-02	0-02 / Castle Street apartments exit	Remove			N/A	Modern fire escape door added	No	4		Door sits within the twentieth century lift and escape stair core. Refer to Dwg C-021 for details of the new proposed door
	ED0-03	0-06 / Cork Hill	Remove	Metal door		Yes	Modern replacement double doors within the nineteenth century Portland stone ope.	No			New replica timber panel double doors with fanlight over within the existing ope to match the panelling detail of the door at Castle street entrance. Refer to Dwg L-221 for details
	ED0-05	0-01 / 0-02	Remove	Modern timber door	FD60S	N/A	Door opening made at the time of the construction of the twentieth century lift and escape stair core.	No	1		New doors within the existing ope to be replica six panel doors. Refer to Dwg C-020 for detail drawing of the proposed doors and photographic survey for details.
	ED1-01	1-02 / 1-03	Remove	Modern Timber door	FD30S	N/A	Door opening made at the time of the construction of the twentieth century lift and escape stair core.	No	1		New doors within the existing ope to be replica six panel doors. Refer to Dwg C-020 for detail drawing of the proposed doors and photographic survey for details.
	ED2-01	2-03/ 2-04	Remove	Modern Timber door	FD30S	N/A	Door opening made at the time of the construction of the twentieth century lift and escape stair core.	No	6		New contemporary escape door in location. Refer to Dwg C-020 for detail drawing of the proposed doors and photographic survey for details.
ED3-01	3-03/ 3-04	Remove	Modern Timber door	FD30S	N/A	Door opening made at the time of the construction of the twentieth century lift and escape stair core.	No	6		New contemporary escape door in location. Refer to Dwg C-020 for detail drawing of the proposed doors and photographic survey for details.	
INTERNAL DOORS											
GROUND FLOOR	D0-01	0-03 / 0-04	Remove	Replacement timber door	FD30S	Yes	Replacement panelled timber door within a stone architrave	No	1		New doors within the existing ope to be replica six panel doors. Refer to Dwg C-020 for detail drawing of the proposed doors and photographic survey for details.
	D0-02	0-04 / 0-05	Missing		FD60S	Yes	Stone architrave	No	1		New doors within the existing ope to be replica six panel doors. Refer to Dwg C-020 for detail drawing of the proposed doors and photographic survey for details.
	D0-03	0-04 / 0-01	Remove	Replacement timber door	N/A	Yes	Existing architrave altered to incorporate the door in the location	Yes	N/A		New pnelled timber double door to be incorporated within the architrave, See Dwg C-022 for details.
	D0-50	0-07	Remove	-	-	-	Replacement door added during a previous fitout	No	N/A		-
	D0-51	0-07	Retain			N/A	Leaded safe door	No	N/A		To be fixed shut
	D0-52	0-06 / 0-07	Remove	Replacement timber door	N/A	Yes	Panelled timber door of some age within the original architrave	No	N/A		Door to be carefully taken down, retained for reuse.
	D0-53	0-05 / 0-06	Remove	Replacement timber door	N/A	Yes	Replacement timber panelled door	No			-

ISSUE	DATE:	NOTE:									
-	16/02/2024	Issue for planning.									
This document needs to be read in conjunction with the general arrangement drawings, component drawings, method statement and the photographic survey. Refer to the Fire consultant report and drawings for further details.											
Note: Door numbers for existing doors is aligned with the proposed door numbering, therefore existing door numbers are not sequential.											
FLOOR	DOOR NO.	LOCATION	STATUS	MATERIAL	FIRE RATING UPGRADE REQUIRED	EXISTING ARCHITRAVE	DESCRIPTION OF EXISTING CONDITION	VISION PANEL	NEW PROPOSED DOOR TYPE (WHERE APPLICABLE)	IRONMONGERY - TBD	NOTES
FIRST FLOOR	D1-01	1-01 / 1-09	Missing	-	FD30S	Yes	-	-	3		New replica six panel timber door in location to match existing panelling detail on door D1-03. To be installed carefully within the architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D1-02	1-05 / 1-06	Missing	-	-	Yes	-	-	3		New replica six panel timber door in location to match existing panelling detail on door D1-03. To be installed carefully within the architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D1-03	1-01 / 1-02	Retain	Timber door	FD30S	Yes	Original panelled timber door within original architrave	No	N/A		Door to be retained in its original location to be upgraded to meet the fire safety standards.
	D1-04	1-01 / 1-06	Remove	Timber door	FD30S. FIXED SHUT DURING FIRE	Yes	Panelled timber door of some age, within the original historic architrave. The curved door reveal is lined with original timber panelling.	No	3		New replica six panel timber door in location to match existing panelling detail on door D1-03. To be installed carefully within the architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D1-05	1-05 / 1-07	Retain	Timber door	FD30S	Yes	Original panelled timber door with original architrave	No	N/A		Door to be retained insitu
	D1-07	1-07 / 1-08	Retain	Timber door	FD30S	Yes	Panelled timber door of some age, within the original historic architrave.	No	N/A		Door to be retained in its original location to be upgraded to meet the fire safety standards.
	D1-08	1-08 / 1-10	Remove	Modern timber door	FD30S	Yes	Replacement door sitting within the original curved architrave in the room.	No	1		New door to be sympathetic to the curved footprint of the oval room. Door to match panelling detail of D01-09. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D1-09	1-09 / 1-08	Retain	Existing curved timber door	FD30S	Yes	Panelled timber door of some age. The door leaf is curved to sit within the plan of the oval room.	No	N/A		Door to be retained in its original location to be upgraded to meet the fire safety standards.
	D1-50	1-02 / 1-04	Remove	Modern timber door	-	No	Modern panelled doors within modern partition walls to be removed	-	N/A		Doors added during previous modern reconfigurations of the building.
	D1-51	1-02	Missing	-	-	Yes	-	-	N/A		-
	D1-52	1-02 / 1-05	Remove	Modern timber door	-	No	Modern panelled doors within modern partition walls to be removed	-	N/A		Doors added during previous modern reconfigurations of the building.
	D1-53	1-09	Missing	-	-	Yes	-	-	N/A		-
	D2-01	2-02/ 2-03	Missing	-	FD30S	Yes	-	-	2		New replica six panel timber door in location to match existing panelling detail on door D2-04. To be installed carefully within the architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D2-03	2-02/ 2-07.A	Missing	-	FD30S	Yes	-	-	2		New replica six panel timber door in location to match existing panelling detail on door D2-04. To be installed carefully within the architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D2-04	2-07 / 2-07.A	Retain	Timber door	FD30S	Yes	Panelled timber door of some age.	No	N/A		Histroic door to be upgraded to a 30 minute fire door to meet the fire safety standards
	D2-05	2-07 / 2-07.B	Retain	Timber door	FD30S	Yes	Panelled timber door of some age.	No	N/A		Histroic door to be upgraded to a 30 minute fire door to meet the fire safety standards

ISSUE	DATE:	NOTE:									
-	16/02/2024	Issue for planning.									
This document needs to be read in conjunction with the general arrangement drawings, component drawings, method statement and the photographic survey. Refer to the Fire consultant report and drawings for further details.											
Note: Door numbers for existing doors is aligned with the proposed door numbering, therefore existing door numbers are not sequential.											
FLOOR	DOOR NO.	LOCATION	STATUS	MATERIAL	FIRE RATING UPGRADE REQUIRED	EXISTING ARCHITRAVE	DESCRIPTION OF EXISTING CONDITION	VISION PANEL	NEW PROPOSED DOOR TYPE (WHERE APPLICABLE)	IRONMONGERY - TBD	NOTES
SECOND FLOOR	D2-06	2-07.A / 2-07.B	Retain	Timber door	FD30S	Yes	Panelled timber door of some age.	Yes	N/A		Histroic door to be upgraded to a 30 minute fire door to meet the fire safety standards
	D2-08	2-08 / 2-10	Remove	Timber door	FD30S	Yes	Timber door of some age with previous alterations	Yes	2		New replica six panel timber door in location to match existing panelling detail on door D2-04. To be installed carefully within the architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D2-09	2-08 / 2-09	Remove	Timber door	FD30S	Yes	Replacement modern timber door	Yes	2		New replica six panel timber door in location to match existing panelling detail on door D2-04. To be installed carefully within the new architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D2-10	2-09 / 2-11	Retain	Existing curved timber door	FD30S	Yes	Panelled timber door of some age. The door leaf is curved to sit within the plan of the oval room. It gives access to an adjacent small storage room.	No	N/A		Histroic door to be upgraded to a 30 minute fire door to meet the fire safety standards.
	D2-11	2-09 / 2-10	Retain	Existing curved timber door	FD30S	Yes	Panelled timber door of some age. The door leaf is curved to sit within the plan of the oval room.	No	N/A		Histroic door to be upgraded to a 30 minute fire door to meet the fire safety standards
	D2-12	2-01 / 2-10	Missing	-	FD30S	Yes	-	-	1		New replica panel timber door in location to match existing panelling detail on door D1-09. To be installed carefully within the architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D2-13	2-01 / 2-02	Remove	Timber Door (fire door)	FD30S	Yes	Modern replacement timber door added during previous refurbishment within the building.	Yes	1		New replica six panel timber door in location to match existing panelling detail on door D1-09. To be installed carefully within the architrave. Refer to Dwg C-020 for detail drawing and photographic survey for details.
	D2-50	2-03 / 2-05	Remove	Timber door	-	-	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	D2-51	2-02	Missing	-	-	-	-	-	N/A		-
	D2-52	2-02 / 2-06	Remove	Timber door	-	-	Timber door of some age	-	N/A		Door of some age to be taken down and retained for reuse.
	D2-53	2-02	Remove	Timber door	-	-	Door under the stairs	-	N/A		-
THIRD FLOOR	D3-01	3-02/ 3-03	Missing	-	FD30S	Yes	-	-	2		New doors to match the panelling details of the existing doors on the floor. Refer to Dwg C-020 and the photographic survey for details.
	D3-03	3-02/ 3-07.A	Missing	-	FD30S	Yes	-	-	2		New doors to match the panelling details of the existing doors on the floor. Refer to Dwg C-020 and the photographic survey for details.
	D3-04	3-07/ 3-07.A	Retain	Timber door	FD60S	Yes	Timber door of some age within the original architrave	No	N/A		Architrave and door system to be upgraded to a 30 minute fire door to meet the fire safety standards
	D3-05	3-07.B/ 3-07.C	Retain	Timber door	FD30S	Yes	Timber door of some age within the original architrave	No	N/A		Architrave and door system to be upgraded to a 30 minute fire door to meet the fire safety standards
	D3-08	3-09/ 3-10.A	Remove	Modern Timber door	FD30S	Yes	Replacement door	No	2		New doors to match the panelling details of the existing doors on the floor. Refer to Dwg C-020 and the photographic survey for details.
	D3-09	3-01/ 3-10.B	N/A	-	FD60S	Yes	-	-	1		New doors to be sympathetic to the existing fabric and to be installed in carefully into the original architrave in the landing. Refer to Dwg C-020 for details.

ISSUE	DATE:	NOTE:
-	16/02/2024	Issue for planning.

This document needs to be read in conjuncture with the general arrangement drawings, component drawings, method statement and the photographic survey. Refer to the Fire consultant report and drawings for further details.

Note: Door numbers for existing doors is aligned with the proposed door numbering, therefore existing door numbers are not sequential.

FLOOR	DOOR NO.	LOCATION	STATUS	MATERIAL	FIRE RATING UPGRADE REQUIRED	EXISTING ARCHITRAVE	DESCRIPTION OF EXISTING CONDITION	VISION PANEL	NEW PROPOSED DOOR TYPE (WHERE APPLICABLE)	IRONMONGERY - TBD	NOTES
THIRD FLOOR	D3-10	3-01/ 3-02	N/A	-	FD60S	Yes			1		New doors to be sympathetic to the existing fabric and to be installed in carefully into the original architrave in the landing. Refer to Dwg C-020 for details.
	D3-50	3-03/ 3-05	Remove	Modern Timber door	N/A	No	Modern timber door	-	N/A		The partition system to be removed
	D3-51	3-05	Remove	Modern Timber door	N/A	N/A	Modern timber door within modern WC block	-	N/A		The partition system to be removed
	D3-52	3-05	Remove	Modern Timber door	N/A	N/A	Modern timber door within modern WC block	-	N/A		The partition system to be removed
	D3-53	3-05	Remove	Modern Timber door	N/A	N/A	Modern timber door within modern WC block	-	N/A		The partition system to be removed
	D3-54	3-05	Remove	Modern Timber door	N/A	N/A	Modern timber door within modern WC block	-	N/A		The partition system to be removed
	D3-55	3-05	Remove	Modern Timber door	N/A	N/A	Modern timber door within modern WC block	-	N/A		The partition system to be removed
	D3-56	3-05	Remove	Modern Timber door	N/A	N/A	Modern timber door within modern WC block	-	N/A		The partition system to be removed
	D3-57	3-02/ 3-06	Remove	Timber door	N/A	Yes	Historic timber door of some age within historic architrave	-	N/A		Door system to be carefully removed and retained on site for reuse
	D3-58	3-07.A/ 3-07.B	Remove	Timber door	N/A	Yes	Historic timber door of some age within the original architrave	-	N/A		Door system to be carefully removed and retained for reuse
	D3-59	3-07.B/ 3-08	Remove	Timber door	N/A	Yes	Historic timber door of some age within the original architrave	-	N/A		Door system to be carefully removed and retained for reuse
	D3-60	3-07.C	Remove	Modern Timber door	N/A	No	Modern timber door within modern WC block	-	N/A		The partition system to be removed
	D3-61	3-07.C	Remove	Modern Timber door	N/A	No	Modern timber door within modern WC block	-	N/A		The partition system to be removed
	D3-62	3-10.A/ 3-10.C	Remove	Modern Timber door	N/A	No	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		The partition system to be removed
D3-63	3-10.A/ 3-10.B	Remove	Modern Timber door	N/A	No	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		The partition system to be removed	
D3-64	3-10.A/ 3-10	Remove	Modern Timber door	N/A	No	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		The partition system to be removed	

ISSUE	DATE:	NOTE:
-	16/02/2024	Issue for planning.

This document needs to be read in conjunction with the general arrangement drawings, component drawings, method statement and the photographic survey. Refer to the Fire consultant report and drawings for further details.

Note: Door numbers for existing doors is aligned with the proposed door numbering, therefore existing door numbers are not sequential.

FLOOR	DOOR NO.	LOCATION	STATUS	MATERIAL	FIRE RATING UPGRADE REQUIRED	EXISTING ARCHITRAVE	DESCRIPTION OF EXISTING CONDITION	VISION PANEL	NEW PROPOSED DOOR TYPE (WHERE APPLICABLE)	IRONMONGERY - TBD	NOTES
BASEMENT	DB-02	B-03/ B-07	Remove	Modern Timber door	FD30S	N/A	Modern replacement timber door added during previous refurbishment within the building.	-			New timber door added. Refer to DWG C-021 for details
	DB-03	B-04/ B-07	Remove	Modern Timber door	FD30S	Yes - Stone	Modern replacement timber door added during previous refurbishment within the building.	-	6		New timber door added. Refer to DWG C-021 for details
	DB-04	B-05/ B-07	Remove	Modern Timber door	FD30S	Yes - Stone	Modern replacement timber door added during previous refurbishment within the building.	-	6		New timber door added. Refer to DWG C-021 for details
	DB-05	B-05.A/ B-07	Remove	Modern Timber door	FD30S	Yes - Stone	Modern replacement timber door added during previous refurbishment within the building.	-	6		New timber door added. Refer to DWG C-021 for details
	DB-06	B-07/ B-08	Remove	Modern Timber door	FD30S	Yes - Stone	Modern replacement timber door added during previous refurbishment within the building.	-	6		New timber door added. Refer to DWG C-021 for details
	DB-09	B-01/ B-07	Remove	Modern Timber door	FD30S	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	6		New timber door added. Refer to DWG C-021 for details
	DB-11	B-01/ B-03	Missing	-	FD30S	Yes - Stone	-	-	6		New timber door added. Refer to DWG C-021 for details
	DB-13	B-01/ B-04	Missing	-	FD30S	Yes - Stone	-	-	6		New timber door added. Refer to DWG C-021 for details
	DB-14	B-01/ B-05	Missing	-	FD30S	Yes - Stone	-	-	6		New timber door added. Refer to DWG C-021 for details
	DB-15	B-01/ B-14	Remove	Modern Timber door	N/A	Yes - Stone	Modern replacement timber door added during previous refurbishment within the building.	-	6		New timber door added. Refer to DWG C-021 for details
	DB-16	B-01/ B-15	Remove	Modern Timber door	FD60S	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	6		New timber door added. Refer to DWG C-021 for details
	DB-18	B-08/ B-10	Missing	-	FD30S	N/A	-	-	6		New timber door added. Refer to DWG C-021 for details
	DB-50	B-05	Remove	Modern Timber door	FD30S	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-51	B-05	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-52	B-05	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-53	B-05	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-54	B-05	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-55	B-01/ B-09	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-

ISSUE	DATE:	NOTE:
-	16/02/2024	Issue for planning.

This document needs to be read in conjuncture with the general arrangement drawings, component drawings, method statement and the photographic survey. Refer to the Fire consultant report and drawings for further details.

Note: Door numbers for existing doors is aligned with the proposed door numbering, therefore existing door numbers are not sequential.

FLOOR	DOOR NO.	LOCATION	STATUS	MATERIAL	FIRE RATING UPGRADE REQUIRED	EXISTING ARCHITRAVE	DESCRIPTION OF EXISTING CONDITION	VISION PANEL	NEW PROPOSED DOOR TYPE (WHERE APPLICABLE)	IRONMONGERY - TBD	NOTES
	DB-56	B-01	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-57	B-01/ B-02	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-58	B-14	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-59	B-14	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-60	B-14.B	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-
	DB-61	B-07	Remove	Modern Timber door	N/A	N/A	Modern replacement timber door added during previous refurbishment within the building.	-	N/A		-

Note all dimensions are indicative only and are to be confirmed on site by contractor.