

| LEGEND | |
|--------|--|
| | EXISTING UNDERGROUND STREET/SITE LIGHTING CABLE ROUTE (SUBJECT TO IDENTIFICATION ON SITE) |
| | EXISTING OVERHEAD STREET/SITE LIGHTING CABLE ROUTE (SUBJECT TO IDENTIFICATION ON SITE) |
| | PROPOSED PUBLIC LIGHTING DUCTING ROUTE. DUCTS SHALL BE UPVC COMPLYING WITH BS3506 CLASS B OR HIG DENSITY POLYTHENE PIPE TO I.S. 135 CLASS B. MINIMUM SIZE 50mm WITH 100mm SPARE DUCTS DEPLOYED AT ROAD CROSSINGS. |
| | PROPOSED PUBLIC LIGHTING DUCTING ROUTE. DUCTS SHALL BE UPVC COMPLYING WITH BS3506 CLASS B OR HIG DENSITY POLYTHENE PIPE TO I.S. 135 CLASS B. MINIMUM SIZE 100mm WITH 100mm SPARE DUCTS DEPLOYED AT ROAD CROSSINGS. |
| | PROPOSED PUBLIC LIGHTING MICRO PILLAR. PROPOSED MICRO PILLAR SHALL BE LOCATED A MINIMUM DISTANCE 21 FROM ESB MINI-PILLARS. |
| | EXISTING ESB NETWORKS MINI-PILLAR AND/OR RECESSED VAULT |
| | PROPOSED ESB NETWORKS MINI-PILLAR & VC2 VAULT ARRANGEMENT |
| | PROPOSED (800x800) CONCRETE DRAW PIT / INSPECTION CHAMBER. |
| | DENOTES PUBLIC LIGHTING LUMINAIRE MOUNTED ON 8M COLUMN |
| | DENOTES PUBLIC LIGHTING LUMINAIRE MOUNTED ON 6M COLUMN |
| | DENOTES PUBLIC LIGHTING BOLLARD |
| | EXISTING STREET LIGHTING POLE |

NOTES RELATING TO STREET LIGHTING INSTALLATIONS:

THE PUBLIC LIGHTING DESIGN SHALL FULLY COMPLY WITH BS5489:2013 LIGHTING CLASS P3.

THE CONTRACTOR SHALL NOTE THAT ALL PUBLIC LIGHTING DUCTING TO BE RED HIGH DENSITY POLYETHYLENE (HDPE) DUCTS STAMPED 'STREET LIGHTING' OR 'PUBLIC LIGHTING' AND BE IN ACCORDANCE WITH DUBLIN CITY COUNCIL PUBLIC LIGHTING REQUIREMENTS.

CONTRACTOR SHALL ENSURE THAT ALL ESNB SUPPLY POINTS, PUBLIC LIGHTING PILLARS, COLUMNS, DUCTS & CABLES ARE INSTALLED/PLACED OUTSIDE THE BOUNDARIES OF PRIVATE PROPERTY.

ALL COLUMNS SHALL BE OF TAPERED OCTAGONAL CONSTRUCTION, FABRICATED FROM 3mm SHEET STEEL OR OF TUBULAR STEEL CONSTRUCTION WITH A MINIMUM WALL THICKNESS OF 3mm. NO CIRCUMFERENTIAL BUTT-WELDING SHALL BE USED IN COLUMN CONSTRUCTION. COLUMNS SHALL COMPLY WITH DCC STREET LIGHTING DIVISION REQUIREMENTS & SPECIFICATIONS.

COLUMNS SHALL HAVE FITTED COMPARTMENT DOORS SET AT A HEIGHT OF 1.5m TO CENTRE OF OPENING ABOVE FINISHED ROAD LEVEL AND NORMALLY FACED AWAY FROM ONCOMING TRAFFIC.

THE OUTSIDE OF THE PLANTED PORTION OF ALL COLUMNS SHALL BE PROTECTED BY A BITUMINOUS COATING EXTENDING TO A HEIGHT OF 150mm ABOVE GROUND LEVEL.

ALL DUCTS SHALL BE PLACED OUTSIDE THE BOUNDARIES OF PROPERTIES AND SHALL NOT AT ANY TIME PASS THROUGH ESB OR EIR TELECOM CHAMBERS.


THE CONTRACTOR SHALL ENSURE THAT SPARE 50mm DUCTS ARE LAID ACROSS ALL DRIVEWAY APRONS. SPARE 100mm DUCT SHALL BE PROVIDED AT EACH ROAD CROSSING. IN ALL SITUATIONS ELECTRICAL HAZARD WARNING TAPE AS PER ET10101:2020 SHALL BE LAID AT THE APPROPRIATE DEPTH.

CABLING DEPLOYED FOR STREET LIGHTING SHALL BE MINIMUM 2x6mm SQ NYCY COMPLYING WITH VDE 0271/5.

A BARE COPPER OR HOT DIP GALV IRON EARTH ROD 16mm DIA SHALL BE SUNK TO A MINIMUM DEPTH OF 1200mm ADJACENT TO EACH SERVICE PILLAR. EARTH RODS SHALL BE INSTALLED WITH SUITABLE INSPECTION BOXES TO FACILITATE INSPECTION OF THE EARTH CONDUCTOR CONNECTION TO THE ROD.

ELECTRICAL CONTRACTOR SHALL REFER TO DUBLIN CITY COUNCIL GUIDELINES FOR PUBLIC LIGHTING WORKS AND ENSURE THAT THEIR INSTALLATION FULLY COMPLIES WITH THIS DOCUMENT.

1 Proposed Site Plan
Scale: 1:500



| | | | | |
|-----|--------------------|----|----|------------|
| P04 | NORTH ADDED | NB | SF | 04.03.2022 |
| P03 | PLANNING ISSUE | NB | SF | 04.02.2022 |
| P02 | PRE PLANNING ISSUE | NB | SF | 21.09.2021 |
| P01 | | NB | SF | 12.04.2021 |

| REV | DESCRIPTION | DRN | CKD | DATE |
|----------------|-------------|-----|-----|------|
| ISSUE | | | | |
| PLANNING STAGE | | | | |



simple mckillop
NATURALLY INNOVATIVE CONSULTING ENGINEERS
Belfast +44 (0)28 90331700
Castleblayney +353 (0)42 9749570
www.semplemckillop.com admin@semplemckillop.com

PROJECT TITLE
NDFA SOCIAL HOUSING PPP BUNDLE 3, EAST WALL ROAD, DUBLIN 3

DRAWING TITLE
SITE LIGHTING DUCTING REQUIREMENTS

| | | |
|--------------------------|-----|----------|
| DRAWING REFERENCE | DRN | SCALE |
| 2746-SMK-XX-ZZ-DR-E-6063 | NB | A1 1:250 |